

MUNICIPAL CORPORATION CHANDIGARH  
(Medical Officer of Health)


(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt. Admn/2022/ 13921

Dated:- 11/10/2022

It is certified that an inspection team headed by Sh. Mohinder Pathak, Health Supervisor from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Carmel Convent School, Sector 9-B, Chandigarh, on 14.09.2022 and mentioned in inspection report that the Carmel Convent School, Sector-9-B, Chandigarh, is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. This certificate is issued with the prior approval of competent authority, Municipal Corporation Chandigarh.

The above Certificate is valid for a period of One-year w.e.f 06-08-2022 (i.e. Water Sampling Date).



Medical Officer of Health  
Municipal Corporation  
Chandigarh

To,

Carmel Convent School  
Sector 9-B  
Chandigarh



MUNICIPAL CORPORATION CHANDIGARH  
Public Health Laboratory at Water Works, Sector 39.

TEST – REPORT

Not for legal use


Ref. No. & Date : - No. CCSC/8705/2022-23 dated 01.08.2022  
Issued to : -  The Principal,  
Carmel Convent School,  
Sector – 9 - B, Chandigarh.  
Quantity of sample : - Approximate 1200 ml.  
Date of Collection : - 03.08.2022  
Client reference : - Sample collected by Laboratory Staff.  
Packing of sample : - Sample filled in P.P. and Glass Bottle.  
Source of sample : - from School tap of Carmel Convent School,  
Sector – 09 - B, Chandigarh.


S. No.	Examination	Quality Standard	Units	Results
1.	Turbidity	<1.0	N.T.U	0.9
2.	pH	7.0-8.5	----	7.78
3.	Residual Chlorine	0.2 – 0.4	mg/L	0.1
4.	Total Alkalinity (as CaCO <sub>3</sub> )	200	-do-	76
5.	Total Hardness (as CaCO <sub>3</sub> )	200	-do-	68
6.	Chlorides (as Cl)	200	-do-	04
7.	Free & Saline Ammonia	Nil	-do-	Nil
8.	Total Dissolved Solids	500	-do-	120
9.	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.08/2022-23/087645, dated 02.08.2022, Amount Rs.3300/-.

Note:- Water is fit for drinking.

Lab. No. MCPHL/22/ 3661  
Dated: -06.08.2022


  
Chemist,  
MCPH Laboratory,  
Chandigarh


  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 2,  
Chandigarh 6/8/22

Inst No. MCPHL/22/ \_\_\_\_\_

Dated \_\_\_\_\_

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

  
Chemist  
MCPH Laboratory  
Chandigarh

  
Sub Divisional Engineer,  
M.C.P.H. Sub Division No. 2,  
Chandigarh